

DETAIL DRAWING SERVICE UNDERGROUND (PERMANENT STRUCTURE)

200 AMP MAXIMUM

①

METER BASE TO BE ATTACHED SECURELY. LEAD ANCHORS OR TOGGLE BOLTS TO BE USED ON BRICK VENEER OR EQUIVALENT. PLASTIC ANCHORS WILL NOT BE PERMITTED.

②

GROUNDING ELECTRODE CONDUCTOR SHALL BE UNSPLICED AND HAVE 6" EXPOSED FOR THE INTERCONNECTION OF OTHER SYSTEMS. ELECTRICAL NON-METALLIC, OR METALLIC CONDUIT SHALL BE USED FOR PROTECTION. IF METALLIC CONDUIT, BOND BOTH ENDS.

③


CONTACT KENERGY FOR CONDUIT SPECIFICATIONS ALL PVC SUBJECT TO PHYSICAL DAMAGE SHALL BE SCH. 80

④

CONTACT KENERGY FOR METERBASE AND UNDERGROUND RISER LOCATION AND BY-PASS REQUIREMENTS

⑤

GROUNDING ELECTRODE SYSTEM (G.E.S.) ALL NEW BUILDING FOUNDATIONS CONTAINING QUALIFIED CONCRETE-ENCASED REINFORCING RODS, MUST BECOME A PART OF THE G.E.S. ALL OTHER INSTALLATIONS MUST CONSIDER PIPE, ROD OR PLATE TYPE G.E.S.



KENERGY CORP

NYLON PULL LINE
RATED @ 50lbs.